

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Audiga Building Material Jiangsu Co., Ltd.

8 Fuye Road, Huangtang, Xuxiake Town, Jiangyin City, Jiangsu, China

For the following product(s):

Vinyl Tile:

Stone Plastic Composite Flooring (*Maximum thickness: 8mm*)

Stone Plastic Composite Flooring with pad (*Maximum thickness: 10mm*)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 v4.2-2023.

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-05029

Valid from: July 01, 2025 to June 30, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink, appearing to read "Diana Kirsanova Phillips".

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services